

## **SPECIFICATION STANDARD**

### **Antennas and Related Equipment**

#### **Antennas and Related Equipment: Installation Guidelines**

The following is offered as guidance to vendors and to campus providers who are seeking to develop sites on the University of New Mexico campus for communication antennas and related equipment. Prepared by the Facilities Management Department (FM), these guidelines address issues under our purview, such as access, utility connection, site impact, etc. It represents one of four review components to develop sites on campus. Other UNM departments involved include Facility Planning, Telecommunications, and the Campus Police. The Department of Planning, Design, and Construction, the Real Estate Office, and the Facilities Management Departments will also make final approvals.

Items listed in these guidelines should be addressed in the preparation of the preliminary plans. All guidelines may not be applicable in all cases, and some installations may require a specific review for site-specific requirements. In most cases, the following criteria should be followed:

#### **General:**

All projects are to be permitted through the State of New Mexico Construction Industries Division (CID). All plans shall be prepared to meet CID requirements for review and permitting. Licensed and insured contractors shall perform all work, with appropriately certified workers. Separate permits for mechanical, plumbing, electrical, low voltage, etc. shall be secured for each project.

Preliminary site investigations shall be scheduled with the appropriate Facilities Management Department maintenance manager. Access to secured areas, such as roofs, electrical closets, etc. shall be provided by the FM manager. Where required, the manager will request that the Facilities Management Department Engineering and Construction Division provide guidance for utility connections, system design, etc.

As part of the preliminary site investigation, items such as the delivery of components to the site via cranes, elevators, etc., should be discussed. FM recommendations should be included in the final drawings to be issued to the contractors. It shall be the responsibility of the vendor and their contractors to repair, replace, or otherwise make whole to any damages caused to the site (buildings, utility distribution systems, or any university property associated with the project). Fees may be assessed for interruption of utilities, which causes a delay in normal university activities.

#### **Site:**

A site map indicating the building location on campus and the site location(s) on or within the building must be included in the construction documents. Crane positioning, existing utility interference problems, etc. should be noted. As-built plans shall be drawn by the vendor's

## **SPECIFICATION STANDARD**

### **Antennas and Related Equipment**

designer and shall include all features to which the Facilities Management Department will need access for maintenance (i.e., roof drains, roof-mounted mechanical and electrical equipment, filter banks, roof hatches, etc.). The plans should indicate parapet wall heights and proximity to the vendor's equipment. If the contractor requires a grade-level construction yard, the area manager, in conjunction with UNM's Parking and Transportation Services, will make specific recommendations for location, length of time, usage fees, etc.

#### **Structural:**

The vendor shall investigate, via research of existing drawings and/or site verification, the suitability of the structural system to sustain the weight of all equipment and building materials to be installed.

Wind loads for all equipment shall be calculated to determine the safe attachment of all new equipment to the roof, walls, parapets, etc. Where necessary, such structural analysis and design, shall be performed by a licensed structural engineer and incorporated into the construction documents.

#### **Roofs, Decks, Weather Proof Membranes:**

For installations on existing roofs, the plans shall indicate the protection of roof surfaces during periods of construction/installation. The plans shall also address the methodology for preventing leaks that may result from vendor installations, and for allowing future reproofing of areas in, around, and under vendor-installed equipment.

For warranty assurance, any roof repairs or reroofing required as a result of vendor installations or related work shall be performed only by a Facilities Management Department preferred roofing contractor.

#### **Architectural:**

The layout of all new equipment shall consider the safety of all workers during and after the construction.

Adequate clearance from edges of roofs, existing and installed equipment, skylights, roof hatches, etc., must be maintained. The height of components on antennas shall be above the adjacent surface, at a level to reassure injury prevention.

Details indicating the method of attachment for all vendor-installed equipment shall be indicated in the plans and reflect actual site conditions and building construction that is pertinent to mounting details. See the "Structural" section for additional information.

## **SPECIFICATION STANDARD**

### **Antennas and Related Equipment**

In instances where the equipment will require the construction of an enclosure, in an area generally visible to the public, the method of construction should be compatible with adjacent construction. Construction shall also be suited to the durability required for the specific site.

#### **Mechanical:**

In cases where HVAC installations for heating and/or cooling need to be made, such installations shall be “free-standing” from the building's mechanical system. Existing utilities, such as natural gas and electrical, may be extended for the vendor's use. Such use shall be evaluated for its impact on existing system capabilities and if allowed will be fully metered and charged.

In cases where the vendor installs HVAC equipment, all maintenance, and repair of such equipment shall be the responsibility of the vendor and their assigned contractors.

#### **Security:**

Keys to access restricted Facilities Management Department areas such as roofs, mechanical rooms, electrical closets, etc., will not be issued, except as required for a period of construction. Access to sites shall be provided by Facilities Management Department personnel, or by the Campus Police. Keys to vendor-constructed secured equipment rooms and areas shall be Sargent-manufactured as specified by the Facilities Management Department and will be keyed to allow emergency access by Physical Plant personnel or by Campus Police.

#### **Electrical:**

All projects shall have preliminary load information (voltage, phase, peak capacity, typical capacity) for all required equipment provided to the Facilities Management Department electrical engineer. Normally, the load must be configured to be 3-phase. The electrical engineer will determine the equipment electrical service method/tie-in point.

A contractor, provided and installed a meter on the main electrical service to the equipment, shall meter electrical service. The meter shall be E-Mon Corporation P-Con, 3-Phase, KWH. No exceptions. Provided with pulse module (for future remote data gathering of KWH and KW demand information via the nearest buildings' EMCS panel). Provide conduit stub out from the meter to the nearest building's EMCS panel. The electrical meter must be in a location readily accessible by Facilities Management Department utility personnel.

If emergency electrical power is required for any vendor-installed equipment, the vendor must provide any such emergency power. No connection to UNM emergency electrical power will be allowed. Individual installations requiring emergency power will need to be evaluated on a case-by-case basis for a method of generation.

### **END OF SECTION**